



1 **EC-TYPE EXAMINATION CERTIFICATE**

2 **Equipment or Protective System Intended for use  
in Potentially Explosive Atmospheres  
Directive 94/9/EC**

3 EC-Type Examination Certificate Number : **BAS01ATEX2108X**

4 Equipment or Protective System: **TYPE PL7\*\* RANGE OF JUNCTION BOXES**

5 Manufacturer: **HAWKE CABLE GLANDS LTD**

6 Address: **Ashton-under-Lyne, Lancashire, OL7 0NA**

7 This equipment or protective system and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

8 The Electrical Equipment Certification Service, notified body number 600 in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment or protective system has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential Report N°

**99(C)0846 dated 15 August 2001**

9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:  
**EN 50014: 1997 + Amds 1 & 2                      EN 50019: 2000                      EN 50281-1-1: 1998**  
except in respect of those requirements listed at item 18 of the Schedule.

10 If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.

11 This EC-TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified equipment or protective system. If applicable, further requirements of this Directive apply to the manufacture and supply of this equipment or protective system.

12 The marking of the equipment or protective system shall include the following:-

**⊕ II 2 GD T80°C                      EEx e II T(see schedule) -20°C ≤ T<sub>amb</sub> ≤ (see schedule)**

This certificate may only be reproduced in its entirety and without any change, schedule included.

File No: EECS 0500/03/051

This certificate is granted subject to the general conditions of the Electrical Equipment Certification Service. It does not necessarily indicate that the apparatus may be used in particular industries or circumstances.



Electrical Equipment Certification Service  
Health and Safety Executive  
Harpur Hill, Buxton, Derbyshire, SK17 9JN, United Kingdom  
Tel: +44(0)1298 28000 Fax: +44(0)1298 28244  
internet: www.bascefa.com e-mail: bascefa.info.eccs@hsl.gov.uk



**I M CLEARE**  
DIRECTOR  
31 August 2001



13

Schedule

14

EC-TYPE EXAMINATION CERTIFICATE N° BAS01ATEX2108X

15

Description of Equipment or Protective System

The **Type PL 7\*\* Range of Junction Boxes** have previously been certified individually, covered by certificate numbers; Ex 92C3483X and Ex 92C3482X. They consist of type ZPL712 plastic enclosures in which are fitted a variety of different terminal arrangements. The empty enclosures are covered by certificate No. BAS01ATEX2102U, coded EEx e II. All the terminals are covered by their own component certificates and are all coded EEx e II. The terminals are listed on drawing No. D2536 held on file 0500/03/054. The actual terminals fitted to each enclosure will be listed in the schedule of the instruction sheets, AI 273, supplied with the enclosure.

The terminals must be used within their relevant temperature range, voltage and current limitations, and fitted in accordance with EN 50019 with regard to creepage and clearance distances. Details on drawing C2540 describe partitioning arrangements which allow for the termination of intrinsically safe (i.s.) circuits and non i.s. circuits within the same enclosure. When i.s. circuits are present an additional label is fitted to the outside of the enclosure stating "INTRINSICALLY SAFE CIRCUIT ENCLOSED".

The maximum power dissipation within each terminal box is as follows:

Box Type	Max. Power Dissipation (Watts)										Cable length per terminal (m)
	T6	amb 40°C	T6	amb 55°C	T5	amb 40°C	T6	amb 65°C	T5	amb 65°C	
PL712	3.35		2.15		4.6		1.2		2.4		0.142

The maximum number of terminals which may be fitted into each enclosure is calculated using the following formula:

$$\text{Power} = I^2 \times N(R_t + R_c) \text{ Watts}$$

where:

I = actual current through the conductor up to the maximum certified current of the terminal (amps)

N = number of terminals

R<sub>t</sub> = terminal resistance (Ohms @ 20°C)

R<sub>c</sub> = resistance of one conductor (Ohms @ 20°C) when using a maximum diagonal cable length listed in the above table

Earth facilities and cable entries are described on the component certificate for the empty enclosures BAS01ATEX2102U. A suitable certified internal rail mounted earth may be used. If a "clean earth" is required a rail mounted power terminal may be used.



13

**Schedule**

14

**EC-TYPE EXAMINATION CERTIFICATE N° BAS01ATEX2108X**

**VARIATION ONE**

When required a component approved breather, drain or breather-drain may be fitted to the enclosure as specified by the component certificate BAS01ATEX2102U. When fitted the IP rating of the enclosure is reduced to the IP rating of the device fitted and may no longer suitable for category 2D.

Fitting a Redapt breather covered by certificate SIRA 99 ATEX 3050U does not effect the IP rating of the enclosure and thus requires no change in marking.

Fitting any of the alternative breathers specified in the certification documents reduces the dust ingress protection to IP5. The designation of the enclosure will be changed as shown below:

add suffix /1 eg. PL712 becomes PL712/1

The marking of the enclosure shall include the following:-

Ⓔ II 2 G 3 D T80°C EEx e II T(see schedule) -20°C ≤ T<sub>amb</sub> ≤ (see schedule)

16

**Report No.**

99(C)0846

17

**Special Conditions for Safe Use**

1. Only the following breathers are approved for use with these enclosures:-

Manufacturer and type	Certificate No.	Code	Dust IP rating
KRON Type DLP	NEMKO Ex 94C086X	EEx e II	5
Tranberg A.S. TEF7302	NEMKO 88.217	EEx e II	5
Weidmuller BD1	BASEEFA Ex 86B3174U	EEx e II	5
Redapt	SIRA 99 ATEX 3050U	EEx e I/II	6

2. The breathers must be installed in their correct orientation in the bottom face of the enclosure. The enclosure IP rating shall match the breather and must be at least IP54.

3. Unused cable entries must be fitted with Hawke Type 375 or Type 387 Stopping Plugs.

4. All terminal screws, used and unused, shall be tightened down by the end user.

5. Insulation of conductors must extend to within 1mm of the metal of the terminal throat unless specified otherwise on the terminal certificate.

6. No more than one single or multistrand lead shall be connected into either side of any terminal unless multiple conductors have been joined in a suitable manner, e.g. two conductors into a single insulated crimped bootlace ferrule or any method indicated on the terminal certificate.



13

**Schedule**

14

**EC-TYPE EXAMINATION CERTIFICATE N° BAS01ATEX2108X**

7. Terminals shall be installed in such a manner that the creepage and clearance distances between the terminal and adjacent components, enclosure walls and covers comply with the requirements of EN 50019 for the rated voltage of the apparatus.
8. Terminal temperatures must not exceed the operating range specified on the component certificate.
9. All terminals, and accessories such as cross-connectors, shall be installed in accordance with the terminal manufacturers instructions. Hawke Cable Glands Ltd will supply the relevant terminal manufacturers instructions with each junction box covered by this certificate.
10. The maximum voltage, current and dissipated power shown on the rating label must not be exceeded.
11. When connecting conductors of cross section below the maximum allowed for a particular terminal then the maximum amps/pole must be reduced in line with the maximum amps permitted for a terminal equivalent to the conductor size fitted. e.g. If a terminal that can take a 10mm<sup>2</sup> conductor at 50 Amps is fitted with a 4mm<sup>2</sup> conductor then the current shall be reduced to a maximum of 21 Amps, or the rating marked on the apparatus label, whichever is the lower.

18

**Essential Health and Safety Requirements**

None that are not covered by assessment against EN 50014: 1997, EN 50019: 2000 and EN 50281-1-1: 1998.

19

**DRAWINGS**

Number	Sheet	Issue	Date	Description
C2540		A	20/7/01	General Arrangement
* AI 273		A	7/01	Instructions

\* common to and held with certificate BAS01ATEX2107X on file 0500/03/047

This certificate may only be reproduced in its entirety and without any change, schedule included.

BASEEFA List Keywords  
2TERMBOX



1 **SUPPLEMENTARY EC - TYPE EXAMINATION CERTIFICATE**

2 **Equipment or Protective System Intended for use in Potentially Explosive Atmospheres  
Directive 94/9/EC**

- 3 Supplementary EC - Type Examination Certificate Number: **BAS01ATEX2108X/1**
- 4 Equipment or Protective System: **TYPE PL7\*\* RANGE OF JUNCTION BOXES**
- 5 Manufacturer: **HAWKE INTERNATIONAL**
- 6 Address: **Oxford Street West, Ashton-under-Lyne, Lancashire, OL7 0NA**
- 7 This supplementary certificate extends EC – Type Examination Certificate No. BAS01ATEX2108X to apply to equipment or protective systems designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

This supplementary certificate shall be held with the original certificate.

The original certificate was issued by The Electrical Equipment Certification Service, Notified Body Number 0600, which retains responsibility for its original documentation. Baseefa (2001) Ltd., Notified Body Number 1180, is responsible only for the additional work relating to this supplementary certificate and any other supplementary certificate it has issued.

This certificate may only be reproduced in its entirety, without any change, schedule included.

Baseefa (2001) Ltd. Customer Reference No. 0500

Project File No. 04/0441

This certificate is granted subject to the general terms and conditions of Baseefa (2001) Ltd. It does not necessarily indicate that the equipment may be used in particular industries or circumstances.

**Baseefa (2001) Ltd.**

Health and Safety Laboratory Site, Harpur Hill,  
Buxton, Derbyshire SK17 9JN  
Telephone +44 (0) 1298 28255 Fax +44 (0) 1298 28216  
e-mail [info@baseefa2001.biz](mailto:info@baseefa2001.biz) web site [www.baseefa2001.biz](http://www.baseefa2001.biz)  
Registered in England No. 4305578 at 13 Dovedale Crescent, Buxton,  
Derbyshire, SK17 9BJ

**R S SINCLAIR**  
**DIRECTOR**  
On behalf of  
Baseefa (2001) Ltd.



13

## Schedule

14

Certificate Number BAS01ATEX2108X/1

### 15 Description of the variation to the Equipment or Protective System

#### Variation 1.1

To clarify that the PL722 comes within the scope of this certificate. The details were omitted in error on the original certificate.

The maximum power dissipation within each terminal box is as follows:

Box Type	Max. Power Dissipation (Watts)										Cable length per terminal (m)
	T6	amb 40°C	T6	amb 55°C	T5	amb 40°C	T6	amb 65°C	T5	amb 65°C	
PL712		3.35		2.15		4.6		1.2		2.4	0.142
PL722		5.32		3.23		7.3		1.9		3.9	0.226

### 16 Report Number

None

### 17 Special Conditions for Safe Use

None additional to those listed previously

### 18 Essential Health and Safety Requirements

Compliance with the Essential Health and Safety Requirements is not affected by this variation.

### 19 Drawings and Documents

None