



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION
IEC Certification Scheme for Explosive Atmospheres
 for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: **IECEX BAS 06.0014X** Issue No.: **0**

Status: **Current**

Date of Issue: **2006-08-07** Page 1 of 3

Applicant: **Hawke International**
 A Division of Hubbell Ltd.
 A member of the Hubbell Group of
 Companies
 Oxford Street West, Ashton-under-Lyne
 Lancashire, OL7 0NA
 United Kingdom

Electrical Apparatus: **Type 501/453UNIV Cable Glands**
 Optional accessory:

Type of Protection: **Ex d, Ex e, Ex tD**

Marking: **Ex d IIC Ex e II Ex tD A21 IP66**
 (- 60°C ≤ ta ≤ + 80°C)


Approved for issue on behalf of the IECEx
 Certification Body:

R S Sinclair

Position:

Managing Director

Signature:
 (for printed version)



 7-8-06

Date:

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

Baseefa (2001) Ltd.
 Rockhead Business Park
 Staden Lane
 Buxton
 Derbyshire
 SK17 9RZ
 United Kingdom





IECEX Certificate of Conformity

Certificate No.: IECEx BAS 06.0014X
 Date of Issue: 2006-08-07 Issue No.: 0

Page 2 of 3

Manufacturer: **Hawke International**
 A Division of Hubbell Ltd.
 A member of the Hubbell Group of Companies
 Oxford Street West
 Ashton-under-Lyne
 Lancashire
 OL7 0NA
 United Kingdom

Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2004 Edition: 4.0	Electrical apparatus for explosive gas atmospheres - Part 0: General requirements
IEC 60079-1 : 2003 Edition: 5	Electrical apparatus for explosive gas atmospheres - Part 1: Flameproof enclosure 'd'
IEC 60079-7 : 2001 Edition: 3	Electrical apparatus for explosive gas atmospheres - Part 7: Increased safety 'e'
IEC 61241-0 : 2004 Edition: 1	Electrical apparatus for use in the presence of combustible dust - Part 0: General requirements
IEC 61241-1 : 2004 Edition: 1	Electrical apparatus for use in the presence of combustible dust - Part 1: Protection by enclosures "tD"

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

GB/BAS/ExTR06.0012/00

Quality Assessment Report:

GB/BAS/QAR06.0061/00



IECEX Certificate of Conformity

Certificate No.: IECEx BAS 06.0014X

Date of Issue: 2006-08-07

Issue No.: 0

Page 3 of 3

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The Type 501/453 Universal Cable Gland may be manufactured in brass, stainless steel or aluminium and is intended for use with an effectively filled and circular armoured or braided cable and comprises the following components:

- a. An entry component, in the size range Os to F (M16 to M75)
- b. A combined silicone inner seal, polymer support ring and metallic armour clamping cone.
- c. A reversible armour clamping ring.
- d. A middle nut.
- e. An outer seal assembly (sleeve seal and support ring).
- f. A back nut.
- g. An optional earth continuity device for use with metallic inner sheathed cables

These glands may be supplied with specified alternative entry thread forms

CONDITIONS OF CERTIFICATION: YES as shown below:

1. These glands are suitable for use within an operating temperature range of -60°C to $+80^{\circ}\text{C}$.
2. When the gland is used for increased safety or dust protection, the entry thread shall be suitably sealed to maintain the ingress protection rating of the associated enclosure
3. Glands for use with braided cables are only suitable for fixed installations, the cable for which must be effectively clamped to prevent pulling and twisting