



Cable Gland Type ICG 623



Flameproof and Increased Safety

CABLE GLAND SELECTION TABLE

Size Ref.	Entry Thread Size		Cable Acceptance Details							'G'		Hexagon Dimensions	
			Inner Sheath/ Cores			Outer Sheath 'B'						Across Flats	Across Corners
	Metric	NPT* Std./ Option	'D' Max. Over Cores	'E' Max. Inner Sheath	Max. No. Of Cores	Standard Seal		Alternative Seal (S)					
						Min.	Max.	Min.	Max.				
Os	M20	1/2"	8.0	8.0	6	3.0	8.0	-	-	57.5	24.0	27.7	
O	M20	1/2"	8.9	10.0	6	7.5	11.9	-	-	57.5	24.0	27.7	
A	M20	3/4"/1/2"	11.0	12.5	10	11.0	14.3	8.5	13.4	56.3	30.0	34.6	
B	M25	1"/3/4"	16.2	18.4	21	13.0	20.2	9.5	15.4	58.9	36.0	41.6	
C	M32	1 1/4"/1"	21.9	24.7	42	19.0	26.5	15.5	21.2	61.7	46.0	53.1	
C2	M40	1 1/2"/1 1/4"	26.3	29.7	60	25.0	32.5	22.0	28.0	62.6	55.0	63.5	
D	M50	2"/1 1/2"	37.1	41.7	80	31.5	44.4	27.5	34.8	72.8	65.0	75.1	
E	M63	2 1/2"/2"	47.8	53.5	100	42.5	56.3	39.0	46.5	75.7	80.0	92.4	
F	M75	3"/2 1/2"	59.0	66.2/65.3	120	54.5	68.2	48.5	58.3	77.7	95.0	109.6	

*Smaller value is applicable when selecting reduced NPT entry option.

General Information

All Metric entry threads are 1.5mm pitch medium fit.
 All dimensions in millimetres (except* where dimensions are in inches).
 Two part sealing compound and assembly instructions are supplied with the cable gland.
 Assembly instruction data sheet No. A.I. 305.

Accessories including locknuts, sealing washers, serrated washers, earth tags, shrouds, adaptors and reducers available. See pages 44 - 48.

Materials & Finishes

The ICG 623 cable gland is manufactured as standard in brass, stainless steel and aluminium.
 NPT entries, nickel plated as standard. Full nickel plating by electroplating or electroless plating is also available, as are other materials on request.

Cable Gland Ordering Examples

Cable Gland Type/Size/Thread

e.g. ICG 623/C/M32
 ICG 623/C/1 1/4" NPT

Cable Gland with Alternative Seal (S)

e.g. ICG 623/C/M32/S
 ICG 623/C/1 1/4" NPT/S

Application

- Outdoor or Indoor use.
- For use with non-armoured elastomer and plastic insulated cables.

For particular use with :-

- Cables that are not effectively filled, compact and/or circular; have tape bedding or have hygroscopic fillers.
 - Cables that exhibit "Cold Flow" characteristics.
 - Enclosures containing an ignition source in gas group II C areas or containing an ignition source in a Zone I area and exceeding 2 litres in volume.
- See technical section of the catalogue for installation rules and regulations.

Features

- Provides a barrier seal between the individual insulated cores within the cable and prevents entry of the products of an explosion into the cable.
- Assembly of the cable gland compresses and distributes the compound evenly to create a barrier seal at the point of entry into the enclosure.
- The compound chamber may be separated from the cured compound to ensure that the chamber has been effectively filled. If required, external voids can be repaired.
- Provides a cable retention seal onto the cables outer sheath.

Technical Data

- Flameproof EExd and Increased Safety EExe. II 2 GD
- Baseefa Certificate No. BAS 01 ATEX 2079X.
- Suitable for use in Zone 1, Zone 2, Zone 21 and Zone 22.
- Suitable for use in Gas Groups IIA, IIB and IIC.
- Construction and test standards EN 50014, EN 50018, EN 50019 and EN 50281-1-1.
- IEC 60079-0, IEC 60079-1 and IEC 60079-7.
- IP66, IP67 and IP68 (30 metres for 7 days) ingress protection to IEC 60529, EN 60529 and NEMA 4X.
- DTS01 deluge protection certified by ITS.
- Operating temperature range -60°C to +80°C as standard.
- Alternative Certification Options Available.
 - Exd IIC/Exe II.
 - BR-Exd IIC/Exe II.
 - AUS-Exd IIC/Exe II.

ICG 623 Cable Gland