



1 **EC - TYPE EXAMINATION CERTIFICATE**

2 **Equipment or Protective System Intended for use in Potentially Explosive Atmospheres
Directive 94/9/EC**

3 EC - Type Examination Certificate Number: **Baseefa05ATEX0237X**

4 Equipment or Protective System: **Type VL104C Range of Luminaires**

5 This certificate is held by: **Victor Lighting**

6 Address: **388 Hillington Road, Glasgow, G52 4BL**

7 This equipment or protective system and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

8 Baseefa (2001) Ltd., Notified Body number 1180, in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment or protective system has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential Report No. 05(C)0690/1

9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

**EN 50014: 1997 + Amendments 1 & 2, EN 50017: 1998, EN 50019: 2000,
EN 50028: 1987 + Amendment 1, EN50281-1-1: 1998**

except in respect of those requirements listed at item 18 of the Schedule.

10 If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.

11 This EC - TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified equipment or protective system. Further requirements of the Directive apply to the manufacturing process and supply of this equipment or protective system. These are not covered by this certificate.

12 The marking of the equipment or protective system shall include the following :

⊕ II 2GD T70°C EEx eqm II T4

This certificate may only be reproduced in its entirety, without any change, schedule included.

Baseefa Customer Reference No. 5421

Project File No. 05/0690

This certificate is granted subject to the general terms and conditions of Baseefa (2001) Ltd. It does not necessarily indicate that the equipment may be used in particular industries or circumstances.

R S SINCLAIR

DIRECTOR

On behalf of

Baseefa (2001) Ltd.

Baseefa

Rockhead Business Park, Staden Lane,
Buxton, Derbyshire SK17 9RZ

Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601

e-mail info@baseefa.com web site www.baseefa.com

Baseefa is a trading name of Baseefa (2001) Ltd

Registered in England No. 4305578 at the above address



13

Schedule

14

Certificate Number Baseefa05ATEX0237X

15 Description of Equipment or Protective System

The Type VL104C Range of Luminaires comprises twin, three and four lamp units of 18W and 36W in emergency and non-emergency units. The rectangular luminaire body is fabricated steel with a polycarbonate or glass diffuser held in an aluminium frame. Ingress protection of at least IP65 is maintained by a closed cell silicone rubber gasket between the diffuser and the aluminium frame and between the aluminium frame and the steel body. The gasket is either self adhesive or adhered to one surface with silicone rvt sealant. The diffuser frame is secured to the body using up to 10 M6 screws.

The luminaire is intended for flush ceiling mounting with the body located in a recess in the ceiling. At least four mounting clamps are provided to fasten the luminaire body in place.

The following non-emergency models are included in the range:

Model	Control Gear	Lamps	Voltage (v)	T _{amb} (°C)	T Class	Max Surface temperature (°C)
Non-modular	2 x LEVA CH12	4 x 18W	220-254 (47-63Hz) or 220-300 dc	-20 to 40	T4	70
	1 x LEVA CH14	2 x 36W				
	1 x LEVA CH12 & 1 x LEVA CH14	3 x 36W				
	2 x LEVA CH14	4 x 36W				
	2 x LEVA CH18	4 x 18W	110-120 (47-63Hz) or 110-150 dc			
	1 x LEVA CH20	2 x 36W				
	1 x LEVA CH18 & 1 x LEVA CH20	3 x 36W				
	2 x LEVA CH20	4 x 36W				
Modular	2 x LEVA CH12	4 x 18W	220-254 (47-63Hz) or 200-300 dc			
	1 x LEVA CH14	2 x 36W				
	2 x LEVA CH14	4 x 36W				
	2 x LEVA CH18	4 x 18W	110-120 (47-63Hz) or 110-150 dc			
	1 x LEVA CH20	2 x 36W				
	2 x LEVA CH20	4 x 36W				

The LEVA electronic control gear is ATEX approved by certificate KEMA00ATEX2121U. It is located beneath a white painted gear tray within the luminaire body. The LEVA ballast is interchangeable with the parallel circuit type ILB with certificate number KEMA00ATEX2121U. The same certificate covers CNEVA electronic control gear incorporating an inverter for use on emergency models. Emergency models have a 6 volt battery made up of 5 Nickel-cadmium batteries connected in series rated at either 4 or 7 Ah. Modified 36W CNEVA types may alternatively use 4Ah batteries. The following emergency models are included in the range:



Model	Control Gear	Battery (Ah)	Lamps	Voltage (v)	T _{amb} (°C)	T Class	Max Surface temperature (°C)				
Non-modular	1 x LEVA CH12 & 1 x CNEVA CH22	4	4 x 18W	220-254 (47-63Hz)	-20 to 40	T4	70				
	2 x CNEVA CH22	2 x 4	4 x 18W								
	1 x CNEVA CH24	7	2 x 36W								
	1 x LEVA CH12 & 1 x CNEVA CH24		3 x 36W								
	1 x LEVA CH14 & 1 x CNEVA CH24		4 x 36W								
	2 x CNEVA CH24	2 x 7	4 x 36W								
	1 x LEVA CH18 & 1 x CNEVA CH21	4	4 x 18W	110-120 (47-63Hz)							
	2 x CNEVA CH21	2 x 4	4 x 18W								
	1 x CNEVA CH23	7	2 x 36W								
	1 x LEVA CH18 & 1 x CNEVA CH23		3 x 36W								
	1 x LEVA CH20 & 1 x CNEVA CH23		4 x 36W								
	2 x CNEVA CH23	2 x 4	4 x 36W								
	Modular	1 x LEVA CH12 & 1 x CNEVA CH22	4	4 x 18W				220-254 (47-63Hz)	-20 to 40	T4	70
		2 x CNEVA CH22	2 x 4	4 x 18W							
1 x CNEVA CH24		7	2 x 36W								
1 x LEVA CH14 & 1 x CNEVA CH24			4 x 36W								
2 x CNEVA CH24			2 x 7	4 x 36W							
1 x LEVA CH18 & 1 x CNEVA CH21		4	4 x 18W	110-120 (47-63Hz)							
2 x CNEVA CH21		2 x 4	4 x 18W								
1 x CNEVA CH23		7	2 x 36W								
1 x LEVA CH20 & 1 x CNEVA CH23			4 x 36W								
2 x CNEVA CH23			2 x 7		4 x 36W						

The CNEVA control gear controls the charging and discharging of the battery providing under-voltage and over-voltage protection and preventing reverse polarity charging of the cells.

ATEX EEx e approved terminals covered by certificates BAS99ATEX2123U, SIRA02ATEX3247U or PTB98ATEX2135U are provided for the connection of the external supply using cables with up to 6 mm² conductors.

Internal wiring is by 1/0.8 solid copper conductor with heat resistant PVC insulation. Looping cables, where required, are 2.5mm² stranded copper conductor with silicone insulation. Through-going wiring is by 2.5mm² or 4mm² flexible conductor with high temperature PVC insulation and heat resistant oversleeve when required. When two conductors enter one terminal way they are fitted with a crimp-on blade connector.

The enclosure is provided with cable entry holes which must be fitted with ATEX EEx e approved cable glands which maintain the ingress protection of the enclosure. Unused entries must be fitted with ATEX EEx e approved stopping plugs.

Variation 0.1

To permit the range of luminaries to be used in a reduced ambient temperature of -40°C.



16 Report Number

05(C)0690/1

17 Special Conditions for Safe Use

1. Emergency luminaires must not be powered up without the battery fitted.

18 Essential Health and Safety Requirements

All relevant Essential Health and Safety Requirements are covered by the standards listed at item 9.

19 Drawings and Documents

Number	Sheet	Issue	Date	Description
B1747	-	-	17/10/2005	Label Details
Baseefa04ATEX0117X	-	-	14/2/2003	The Curie Range of Recessible Luminaires Certificate
Baseefa04ATEX0117X/1	-	-	23/8/2004	Supplementary Certificate to The Curie Range of Recessible Luminaires Certificate